

Table1: Bypasses and Overflows with Volumes in cubic metres and duration in hours for 2020

Site	Date	Duration Hrs.	Raw overflow Volume	Raw bypass Volume	Primary Treated Overflow Volume	Raw overflow Volume	Primary Bypass (Secondary Treated) Volume
Pond Mills PS	11-Jan-20	0.45	289			289	
Medway PS	11-Jan-20	41.30	13,879			13,879	
Berkshire PS	11-Jan-20	17.90	1,460			1,460	
Pottersburg WWTP	11-Jan-20	40.05	52,718			52,718	
Adelaide WWTP	11-Jan-20	36.95			24,808		
Adelaide PS	11-Jan-20	26.50	not available			not available	
Vauxhall WWTP	11-Jan-20	36.10			557		
Dingman PS Pond	12-Jan-20	23.73					
Greenway WWTP	11-Jan-20	85.00		246			
Vauxhall WWTP	22-Mar-20	5.83					407
Medway PS	29-Mar-20	0.18	44			44	
Berkshire PS	29-Mar-20	1.58	86			86	
Adelaide WWTP	29-Mar-20	4.98					
Vauxhall WWTP	29-Mar-20	2.70					1,548
Vauxhall WWTP	07-Apr-20	1.70	91		474	91	2,583
Pottersburg WWTP	07-Apr-20	0.87	54			54	
Pottersburg WWTP	18-May-20	37.50	3,178			3,178	
Vauxhall WWTP	10-Jun-20	1.18	363			363	1,654
Vauxhall WWTP	10-Jun-20	1.32					1,948
Vauxhall WWTP	19-Jun-20	0.87	1			1	1,215
Vauxhall WWTP	08-Jul-20	0.12					64
Vauxhall WWTP	10-Jul-20	0.93	20			20	1,274
Vauxhall WWTP	19-Jul-20	0.30					170
Vauxhall WWTP	23-Jul-20	0.77					929
Oxford WWTP	23-Jul-20	1.08					
Vauxhall WWTP	01-Aug-20	10.27	2,115			2,115	4,476
Pottersburg WWTP	02-Aug-20	2.88	3,529			3,529	
Pond Mills PS	02-Aug-20	0.97	705			705	
Berkshire PS	02-Aug-20	0.40	106			106	
Vauxhall WWTP	09-Aug-20	1.60					2,166
Vauxhall WWTP	27-Aug-20	0.50					350
Vauxhall WWTP	28-Aug-20	1.25					1,326
Berkshire PS	02-Sep-20	0.60	106			106	
Byron PS	02-Sep-20	1.10	431			431	
Pottersburg WWTP	02-Sep-20	2.65	2,852			2,852	
Vauxhall WWTP	02-Sep-20	9.50	1,458			1,458	5,054
Greenway WWTP	02-Sep-20	3.25		46			24,989
Vauxhall WWTP	07-Sep-20	1.50					2,067
Vauxhall WWTP	13-Sep-20	0.07					7
Vauxhall WWTP	14-Sep-20	0.08					9